

CERTIFICATE OF COMPLIANCE

Certificate Number EX9172
Report Reference EX9172-20070614
Date 2020-November-18

Issued to: JINAN MEIDE CASTING CO LTD
Meide Science and Technology Park
Pingyin Industrial Park
JINANSHANDONG 250400 CN

This is to certify that representative samples of FITTINGS, UNION
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 860 - Standard For Safety For Pipe Unions For Flammable And Combustible Fluids And Fire-Protection Service

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE


Certificate Number EX9172
Report Reference EX9172-20070614
Date 2020-November-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Models:

| Model | Material | Type | Size (in.) | Marked Pressure | Rated Pressure, psig |
|--------------------|----------|----------------|---|-----------------|----------------------|
| / | MI | Union | 1/2, 3/4, 1, 1-1/4, 1-1/2, 2 | 150 | 500 |
| / | MI | Union | 2-1/2, 3 | 150 | 300 |
| 342/U2 | DI | Union | 1, 1-1/4, 1-1/2, 2 | 150 | 300 |
| 342-300/ U2-300 | MI | Union | 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 | 300 | 300 |
| 340 | MI | Union | 1/8, 1/4, 3/8, 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 | 250 | 500 |
| 342 | MI | Union | 1/4, 3/8, 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 | 250 | 500 |
| 341 | MI | Union | 1/4, 3/8, 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 | 250 | 500 |
| 96 | MI | Elbow Union | 1/4, 3/8, 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 | 250 | 500 |
| 98 | MI | Elbow Union | 1/4, 3/8, 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 | 250 | 500 |

MI - Malleable Iron
DI - Ductile Iron



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

